

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3550-0801:196 Page 1 of 1

CATEGORY: Door Closer/Holders

LISTEE: Radionics, Div. Detection Systems, Inc., 130 Perinton Pkwy, Fairport, NY 14450-9199
Contact: Frank Mioduszewski *(585) 223-4060 Fax (585) 421-4263

DESIGN: Models D370B, D370C, D371B, D371C, D372B, D372C door closer/holders. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24V AC/DC, 110VAC

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances. The unit is intended to be mounted in a horizontal position only.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as door closer/holders for use with separately listed compatible detectors and fire alarm control units.

XLf: 3550-1039:100

*Rev. 05-31-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager